

THEATER AND STAGE CURTAINS

FABRICS

- A. 25.5-ounce 100% polyester Dante velour as distributed by Pittsburgh Stage, Inc. Color to be chosen by the Architect. Lining where specified shall be 100% polyester Janus (black in color) as distributed by Pittsburgh Stage, Inc.
- B. 14.5-ounce 100% polyester Volcano velour as distributed by Pittsburgh Stage, Inc. (black in color).
- C. All fabrics of their various kinds and colors shall each be from one and the same dye lot. When materials of one color exceed limit of one dye lot, the balance must be identically matched with the original lot. No "run of the mill" usage of colors will be acceptable.
- D. All combustible fabrics shall be chemically flameproofed by immersion for compliance with all applicable codes. Spray method of flameproofing is unacceptable. This contractor shall furnish flameproofing certificates, giving name of flameproofing chemical used, identification of flameproofing method, method of flameproofing used, and date.

STAGE DRAPERY FABRICATION

- A. Front curtain ensemble and Cyclorama setting shall contain no less than 50 percent sewn-in fullness.
- B. No smaller than half widths shall be used in construction of curtains.
- C. Knife pleats shall be at 12" centers with heavy 3" polypropylene webbing at heading. Headings shall be finished with grommets and "S" hooks; grommets and tie lines; or plain as required. Grommet shall pass through three full layers of face fabric. All vertical seams shall be hidden within the fold of the pleats. "Round pleats" formed by hanging two grommets from one "S" hook is not acceptable.
- D. Grommets shall be black. No smaller than #3 toothed grommet shall be used.
- E. Tie lines shall be black 5/8" polyester braid.
- F. All Traveler curtains shall have one-half width turn-back at on and off stage edges in addition to specified fullness.
- G. Front curtain shall have 6" bottom hems. Valance and/or teaser shall have 4" bottom and side hems.
- H. Cyclorama curtains shall have 4" bottom hems with a #8 jack chain encased in a separate "pocket" suspended 2" from the bottom of the curtain. The use of galvanized lead weights is not acceptable. All other hems are to be 2".
- I. There shall be no horizontal seams unless indicated.

J. A separate 3" x 54" flameproof strip shall be sewn to the off-stage bottom hem of each type of curtain for the purpose of removing samples for testing.

K. Thread shall be glazed, left twist, #24.

FINISHED DIMENSIONS

As existing.

<u>ITEM</u>	<u>QUANTITY</u>	<u>FABRIC</u>
Front Curtain	2	A
Teaser	1	A
Side Legs	6	B
Ceiling Borders	2	B
Olio Valance	1	B
Olio Curtain	2	B
Mid-stage Curtain	2	B
Rear Curtain	2	B

WARRANTEE

The completed installation and curtains shall be guaranteed against defects in material and workmanship for a period of THREE (3) years.